



We hereby confirm that the

Hilti screw anchor HUS-I 6x35 M8/M10
with M8/M10 stepped thread

in the version steel, galvanised,
when used in accordance with European Technical Approval

ETA-10/0005

complies with the guidelines of VdS Schadenverhütung GmbH, 50735 Cologne¹⁾
for fastening pipes
up to DN 50 (connection with M8 anchor rod) and
up to DN 100 (connection with M10 anchor rod)
for water extinguishing systems to reinforced concrete substructures,
e.g. concrete slabs.

Hilti Deutschland GmbH
D-86916 Kaufering

ppa. Martin Reuter

Dipl.-Ing. Construction Sector SFI
Head of Associations, Approvals

p.p. Michael Liebig

Dipl.-Ing. Construction Sector (FH)
Product Manager Metal Plugs

¹⁾ VdS CEA 4001:2010-11:
Guidelines for sprinkler systems, planning and installation, Section 15.2.4