

L	Conduits Through Rigid Floor	IS:SP-RF-E-02	
INFORMATION: - Not to scale - All units are in millimetres	CFS-IS Intumescent Sealant	REV: 01	10/2024
- Tested according EN 1366-3 - Approval ETA-10/0406	Fire Rating up to El 120	Page 1/2	





Conduit Type / Ø	Classifcation	
Small steel conduits and tubes ≤ Ø 16, arranged linear, with or without cables*	EI 90 C/U	
Small plastic conduits and tubes ≤ Ø 16, arranged linear, with or without cables*	EI 90 U/C	

* All sheathed cable types currently and commonly used in building practice in Europe (e.g., power, control, signal, telecommunication, data, optical fibre)

Max opening size 150mm x 150mm or circular openings of equivalent area (Ø 165 mm).

Min 100mm distance to other firestopping penetrations.

Min. 200mm to other penetrations (e.g., doors, windows etc.)

Hilti (Gt. Britain) Limited | No 1, Circle Square | 3 Symphony Park | Manchester | M1 7FS

Freephone: 0800 886 100 | Website: www.hilti.co.uk

^{1.} The application limits on this detail are for guidance purposes only. For more detailed information based on the full range of available test results please contact the Hilti Technical Advisory Service.

2. The product and application has been assessed as a minimum to the BS 476 standard. It may have additional European and worldwide testing. Please contact Hilti for further information.

3. All installations should be carried out in accordance with Hilti's installation instructions and by competent & experienced installers using Hilti branded products.

4. All services are to be correctly and adequately supported to prevent collapse and distortion.